

BOROUGH OF SURF CITY, COUNTY OF OCEAN, NJ

813 Long Beach Boulevard, 08008 Telephone (609)494-3064 Email Frontdesk@surfcitynj.org

Rental Application & Certification in Lieu of Inspection

Single Family Home Fees: ✕ \$45.00 Duplex Fees: ✕ \$90.00

Dwelling Location Block _____ Lot _____ First day of Rental _____

Surf City Rental Street Address _____

*NOTE: ALL BOXES MUST BE CHECKED IN ORDER FOR THE CERTIFICATION TO BE VALID

- Smoke detector on each level of the dwelling, including basements, excluding attic or crawl space; and
- Smoke detector and carbon monoxide alarm outside each separate sleeping area; and within 10 feet of bedrooms
- All smoke detectors are in working order
- All Carbon monoxide alarm(s) are in working order
- Fire extinguisher is the correct size, is properly mounted and is located within 10 feet of the kitchen

This is a _____ story dwelling with without a basement

Single Family: Duplex:

An inspection shall be conducted by the owner or an authorized representative of the owner. The smoke detectors required above shall be located in accordance with NFIPA 74; the carbon monoxide alarm(s) installed per NFPA-720. The detectors are not required to be interconnected. Battery powered detectors and alarms are acceptable. Note: AC powered and/or interconnected alarms and smoke detectors installed in homes constructed after January 1977, shall be maintained in working order. The fire extinguisher is installed per P.L. 2005, c.71 (N.J.S.A. 52:27D-198.1 et seq). See diagram on back of this application for further information regarding installation.

Mailing address _____

Phone Number _____

Email Address _____

Contact person _____

Phone Number _____

I would request my certificate be: (please choose one) emailed faxed in-person pick up

I do hereby certify that the foregoing statements made by me are true. I am aware that if any of the foregoing Statements made by me are willfully false, I will be subject to penalty.

Applicant Name

Notary:
Sworn to and subscribed before me this
_____ day of _____, 20____.

Notary Seal:

Applicant Signature

Signature

Once issued, a Certificate is not transferrable, nor is a fee refundable.

Date Received _____

FOR OFFICE USE ONLY

Check Number _____

Certification Number _____

Issuing Agent _____

Effective January 1, 2019, the following requirement regarding battery-operated smoke alarms will be enforced under the new NJ Uniform Fire Code Requirements.

N.J.A.C. 5:70-4.19 Smoke alarms for one- and two-family dwellings; carbon monoxide alarms; and portable fire extinguishers:

SMOKE ALARM REQUIREMENTS:

(a) In one- and two-family or attached single family dwellings subject to the requirements of N.J.A.C. 5:70-2.3, smoke alarms shall be installed as follows:

1. On each level of the premises; and
2. Outside of each separate sleeping area.

(b) The smoke alarms required in (a) above shall be located and maintained in accordance with NFPA 72.

1. The alarms shall not be required to be interconnected.

(c) 10-YEAR SEALED BATTERY-POWERED SINGLE STATION SMOKE ALARMS shall be installed and shall be listed in accordance with ANSI/UL 217, incorporated herein by reference. However, A/C-powered single or multiple-station smoke alarms installed as part of the original construction or rehabilitation project shall not be replaced with battery-powered smoke alarms. The effective date of this subsection shall be January 1, 2019.

1. A/C-powered smoke alarms shall be accepted as meeting the requirements of this section.

CARBON MONOXIDE ALARM REQUIREMENTS:

Carbon monoxide alarms shall be installed in all dwelling units in buildings in one- and two-family or attached single family dwellings, except for units in buildings that do not contain a fuel-burning device or have an attached garage, as follows:

1. Single station carbon monoxide alarms shall be installed and maintained in the immediate vicinity of the sleeping area(s).
2. Carbon monoxide alarms may be battery-operated, hard-wired or of the plug-in type and shall be listed and labeled in accordance with UL-2034 and shall be installed in accordance with the requirements of this section and NFPA-720.

PORTABLE FIRE EXTINGUISHER REQUIREMENTS:

A portable fire extinguisher shall be installed in accordance with the following:

1. The extinguisher shall be within 10 feet of the kitchen and located in the path of egress;
2. The extinguisher shall be readily accessible and not obstructed from view;
3. The extinguisher shall be mounted using the manufacturer's hanging bracket so the operating instructions are clearly visible;
4. The extinguisher shall be an approved listed and labeled type with a minimum rating of 2A-10B:C and no more than 10 pounds;
5. The owner's manual or written operation instructions shall be provided during the inspection and left for the new occupant;
6. The extinguisher shall be serviced and tagged by a certified Division of Fire Safety contractor within the past 12 months or the seller must have a receipt for a recently purchased extinguisher; and
7. The top of the extinguisher shall not be more than five feet above the floor.

To avoid potential false alarms and improper operation, do not install smoke alarms in the following areas:

- Kitchens - Smoke from cooking may cause a nuisance alarm.
- Bathrooms - Excessive steam from a shower may cause a nuisance alarm.
- Near heating or air conditioning ducts
- The "Dead Air" space where the ceiling meets the wall (see Figure 5).
- The peak of an "A" frame ceiling at the top may prevent smoke from reaching the detector.




Figure 1




Figure 2




Figure 3




Figure 4




Figure 5